

CLARIFICATIONS AND INTERPRETATIONS

Invitation for Bids FQ19023/GG – DULLES RAILYARD WAREHOUSE AND RACK SHELVING

Request for Clarification No's 1 – 12

The following clarifications and/or interpretations are provided in response to questions that have been received in reference to IFB FQ19023/GG:

Q#	Questions	WMATA Responses or Clarifications
1	Will the beam/ shelf / and arm elevations on all the storage equipment on the plans be provided so engineering prlims and calcs can be done.	Please refer to SOW Attachment B for the equipment cutsheet for the dimensions and minimum loading requirements.
2	What type/brand/ model of forklift equipment will be used with the racking?	WMATA will be utilizing various forklift equipment for material handling storage and operations within the Warehouse facility, including but not limited to: <ul style="list-style-type: none">▪ Forklift, Electric, Riding, 10,000 lb – Clark GEX 50▪ Forklift, electric, 4,000 lbs – Clark ECX 20▪ Forklift, electric, standing, 4,000 lbs - Clark NPX 20▪ Forklift, stock picker - Crown SP 3500-30▪ Lift, pallet, electric, 4,500 lbs – Clark WPX 45
3	Given that the delivery of this material will be in January 2019 will inside storage be provided to protect against winter conditions?	The building will be fully enclosed at the time of installation. The Shelving Installer will have access to deliver the shelving materials into the spaces at the time of installation.
4	Will drawings be provided showing dimensions of the rooms and equipment where the material will be installed?	Yes, See FYI_ONLY base building drawings attachments on www.wmata.com under solicitation FQ19023.
5	Pre-bid walkthrough question: Will area be clear when installation starts?	Yes.
6	Pre-bid walkthrough question: Will we be able to get access to conduct measurement after award of project?	Yes, after contract award.

7	Pre-bid walkthrough question: Can we structural calculations of slab be provided?	Structural calculations for the building slab will be provided to the successful bidder at the time of award.
8	Pre-bid walkthrough question: What's the requirement for the rack base protection?	See Amendment Number 001
9	Pre-bid walkthrough question: Do rack pallets need to be painted finish?	See Amendment Number 001
10	Pre-bid walkthrough question: Are we requiring rack pallet row spacers?	See Amendment Number 001
11	Pre-bid walkthrough question: Please confirm anchor requirements.	See Amendment Number 001
12	Pre-bid walkthrough question: Can you please provide building sections of the warehouse?	See answer to question number 4