



CENTRAL VIRGINIA  
LABORATORIES & CONSULTANTS, INC.

April 12, 1996

Carla A. Grano  
WMATA (ENSV)  
3101 Eisenhower Ave.  
Alexandria, Virginia 22314

Dear Ms. Grano:

Enclosed are analytical results for the asbestos sample collected March 30, 1996.

If you should have any questions or require additional information, please do not hesitate to contact me.

Sincerely,

Ted M. Schumacher  
Laboratory Director

TMS/sts  
enclosures

ANALYTICAL RESULTS

FOR

WMATA (ENSV)

April 12, 1996

Prepared By:

Central Virginia Laboratories & Consultants, Inc.  
3109 Odd Fellows Road  
Lynchburg, Virginia 24501  
(804) 847-2852

<i>CVLC #</i>	<i>Client ID</i>	<i>% Asbestos Fibers</i>		<i>% Other Fibers</i>	<i>% Non-Fibrous Material</i>
96-02821	RPL - 01	Chrysotile	>1-5*	Other fibers	ND, <1
		Amosite	ND, <1		95-99
		Crocidolite	ND, <1		
		<u>Total</u>	<u>&gt;1-5</u>		
		* WHITE COAT			
96-02822	RPL - 02	Chrysotile	5*	Other fibers	ND, <1
		Amosite	ND, <1		95
		Crocidolite	ND, <1		
		<u>Total</u>	<u>5</u>		
		*WHITE COAT			
96-02823	RPL - 03	Chrysotile	5*	Other fibers	ND, <1
		Amosite	ND, <1		95
		Crocidolite	ND, <1		
		<u>Total</u>	<u>5</u>		
		* WHITE COAT			

ND = Not Detected, <1%

If the above samples are building materials regulated by EPA's NESHAP regulations (renovation/demolition), the results may be biased on the high side. You may opt to have samples with less than 10 percent asbestos re-analyzed by the reportedly more accurate point count procedure in the EPA Interim Method for the identification of Asbestos in Bulk Materials.

<i>Collection Information</i>				
<u>CVLC #</u>	<u>Client ID</u>	<u>Location</u>	<u>Sample Date</u>	<u>Sample Time</u>
96-02821	RPL - 01	2nd floor	03/30/96	NG
96-02822	RPL - 02	2nd floor	03/30/96	NG
96-02823	RPL - 03	2nd floor	03/30/96	NG

NG = Not Given

TB62212927US

Company Contact: CARLA GLAND

Project Number:	Project Name:
-----------------	---------------

Project Name: ROYAL STREET DIVISION

Carla A. Ward / CA Gland

[illegible]

Temperature upon receipt:

Date/Time 4/1/96 1330

Date/Time

Date/Time:

P.O. No.

5/11/2631501 7HWA 27787

Comments:  
please fax results to C Glavo  
at (202) 962-5000 no later than  
4/10/96.

# Central Virginia Laboratories & Consultants

3109 Odd Fellows Road  
Lynchburg, Virginia 24501